4. BASESLAB THICKNESS=6" REINFORCED w/#5 GRADE 60 REBAR @ 9" O.C.E.W.

5. MANHOLE STEPS, (WHEN REQUIRED), @ 12" c.c., ALWAYS @ 0° 6. INTERIOR and/or EXTERIOR COATED WHEN NEGOTIATED.



48"Ø MANHOLE SPECIFICATIONS

